




Accelerating Electrification of CA's Multifamily Buildings

Technical Guidelines

June 8, 2022

Part 2 – Technical Considerations for the Electrification of Existing MF Bldgs

- Electricity fundamentals
- Cost-Efficient Electrification Overview (Decision Tree)
- 4 step process



Step 1 – Evaluate Existing Conditions

- Typical existing infrastructure (80/20 rule)
- Planned modernization
- Data collection, usable 3pg form:
 - Main panel and subpanel capacities
 - Equipment specifications
 - Wiring types
- Identifying elect. infrastructure

Data Collection	Data Applications
APARTMENT AND COMMON AREA LOADS	
<input type="checkbox"/> Wall construction: __ inches of insulation <input type="checkbox"/> No cavity/difficult access (brick, lath+plaster, etc.)* <input type="checkbox"/> Ceiling construction: __ inches of insulation <input type="checkbox"/> Has accessible cavity* <input type="checkbox"/> Floor: __ inches of insulation <input type="checkbox"/> Slab <input type="checkbox"/> Window glazing: <input type="checkbox"/> Single pane <input type="checkbox"/> Dual pane <input type="checkbox"/> Window frame: <input type="checkbox"/> Metal <input type="checkbox"/> Wood <input type="checkbox"/> Vinyl or fiberglass	
<input type="checkbox"/> Primary lighting type: <input type="checkbox"/> Incandescent <input type="checkbox"/> Fluorescent <input type="checkbox"/> LED (1) <input type="checkbox"/> Do residents report tripping electrical breakers? <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> If so, when? _____ (2) <input type="checkbox"/> Range: <input type="checkbox"/> Gas <input type="checkbox"/> Electric <input type="checkbox"/> Water heating BTU output: _____ <input type="checkbox"/> Gas <input type="checkbox"/> Electric <input type="checkbox"/> In unit <input type="checkbox"/> Central <input type="checkbox"/> Heating type: <input type="checkbox"/> Gas <input type="checkbox"/> Electric <input type="checkbox"/> Hydronic <input type="checkbox"/> Steam <input type="checkbox"/> Ducted <input type="checkbox"/> Heating output: _____ <input type="checkbox"/> Cooling output: _____ (3)	(1) Extra capacity may be gained by upgrading to LEDs if lights are not already efficient. (2) If certain breakers frequently trip, their circuits may be overloaded or have safety issues. (3) Knowing which appliances use gas, and how much they use, can help inform calculations of how much electricity use will be added once these appliances are converted to electric. Keep in mind, existing gas appliances tend to be oversized, so the best practice is to resize when installing new electrical appliances.




Figure 8. Electrical Infrastructure Sequence

Helpful “real-world” photos throughout




Figure 20. Service Disconnect and Switchboard of a Large Multifamily Building




Figure 14. Photograph and Diagram of Inside of a Subpanel

(Square D, 2020) (Square D, 2020) (Saltzman) (Murray, 2020)



Figure 23. Pole-Mounted Transformer




Figure 11. Panel Showing Single- and Dual-Pole Breakers

Step 2 – Analyze Electrical Load

- NEC deemed electrical load calculation, 2 examples fully detailed
- NEC electrical load monitoring study
- References in works cited and appendix




Figure 26. Load Monitoring Equipment

Residential Dwelling Unit Load Calculation - NEC Section 220			
Dwelling Unit Area	800 ft ²		
Step 1 - General Loads Per NEC 220.16			
Deemed Lighting Load Value: 3.0 Volt Amps (VA) per square foot		=	2,400 VA
Kitchen Appliance Circuit	Quantity: 2	NEC Deemed VA Value: 1,500	= 3,000 VA
Laundry Appliance Circuit	Quantity: 1	NEC Deemed VA Value: 1,500	= 1,500 VA
Demand factors:			
First 3 KVA have a demand factor of 100%			3,000 VA
≥ 3 & < 120 KVA have a demand factor of 35%			3,900 VA
≥ 120 KVA have a demand factor of 25%			- VA
		Total	= 4,365 VA
Step 2 - HVAC Loads Per NEC 220.83b			
Added Load from Space Heating Electrification		Quantity	Appliance Name Plate VA
3-Ton Mini-split Heat Pump for Heating and Cooling		1	+ 4,000 = 4,000 VA
Demand factors:			
Electric heating or cooling (whichever is larger) has a demand factor of 100%			4,000 VA
Less than 4 Appliances Fixed in Place 100% NP Rating			- VA
4 or More Appliances Fixed in Place 75% NP Rating			- VA
		Total	= 4,000 VA
Step 3 - Electric Cooking Loads Per NEC 220.55			
Electric Cooking Range and Stovetop		Quantity: 1	Deemed VA Rating: 12,000 = 12,000 VA
Demand factors:			
Electric Cooking Appliance has a demand factor of 100%			12,000 VA
		Total	= 12,000 VA
Step 4 - Add the Results from Step 1 through 3 to Calculate Required Volt Amps and Amps			
Total Existing Volt Amps for the Dwelling Unit			16,365 VA
Total Proposed Volt Amps for the Dwelling Unit with the 3-Ton Mini-split Heat Pump			20,365 VA
Single Phase Amp Capacity Requirements			84.85 A
In-unit Subpanel Amp Rating			100.00 A
Secondary Disconnect and Feeder Wire Amp Rating			75.00 A

Notes for Example A

Step 1: General Loads are required by the NEC. These are intended to serve small plug-in appliances throughout the dwelling unit.

Demand factors: For each load type, demand factors are applied to help simulate the coincidence that all loads will be on at the same time. Different load types have different demand factors deemed by the NEC.

Step 2: HVAC Loads have different demand factors and must be calculated separately from general loads. For all NEC load calculations, the calculation must represent the final conditions. In this example, the 3-ton heat pump replaces the existing furnace during electrification.

Step 3: Electric Cooking also has different demand factors and must be calculated separately from HVAC Loads and General Loads.

Step 4: Sum all loads after demand factors have been applied to determine the total volt amps for the dwelling unit. Divide this number by the volt ratings of the panel/secondary disconnect to determine required amps. In this example, it is being divided by single phase 240V.

Step 3 – Select Efficiency Measures and Appliances

- HVAC efficiency and equipment
- Domestic Hot Water systems
- Lighting, cooking, appliances + misc. equipment
- Includes system-specific considerations: climate, electrical requirements, equipment selection, and efficiency opps.




Figure 30. 1.5 to 3 Ton Split AC Replaced with Heat Pump with Efficiency Measures Applied

Images and data: (Goodman, 2020) (Goodman, 2020) (Mitsubishi Electric, 2020)

HVAC

- HVAC Efficiency and Equipment
- Design Considerations
 - Envelope Penetrations (Packaged Systems)
 - Location of Outdoor Compressor (Split Systems)
 - Refrigerant Line sets (Split Systems)
 - Cold Ambient Performance
 - Defrost Cycle



DHW

- Domestic Hot Water Efficiency and Product Selection
- Residential & Commercial HPWH Considerations
 - Electrical Requirements
 - Equipment Location
 - Cold Ambient Temperature Performance



Lighting, cooking, appliances and misc. equipment

- **Efficiency Opportunities**

- Lighting
- Cooking
- Laundry
- Misc. - Fan Efficiency and Pumps

- **Electrification Opportunities**

- Cooking
- Laundry
- Pool/Spa Heaters



Existing Residential Washing Machine and Electric Resistance Clothes Dryer



Proposed Residential Condensing Dryer/Washer Combination

	Existing	Proposed	Capacity & Infrastructure Savings
Total Watts	5,700	1,200	+ 4,500
Breaker	<ul style="list-style-type: none"> • 240V 30 Amp (Dryer) • 120V 15 Amp* (Washing Machine) 	120V 15 Amp*	+ 1 Single Pole Breaker Slot

**These efficiency measures are typically not reflected in NEC calcs due to deemed electrical loads*

Case Studies

ALMOND COURT

Wasco, CA

Owner: Self-Help Enterprises
 Year built: 1996
 Type: Low-rise multifamily
 Sector: Affordable rental
 Units: 36
 Size: 45,000 sq. ft.
 Program participation: Low Income Weatherization Program (LIWP)



PROJECT SCOPE

- ◆ Heat pump water heaters
- ◆ High efficiency ducted heat pumps
- ◆ Ductwork sealed with Aeroseal
- ◆ Attic air sealed and insulated
- ◆ ENERGY STAR washing machines and refrigerators
- ◆ Dual-pane windows
- ◆ Comprehensive LED lighting upgrade
- ◆ Low-flow aerators and showerheads
- ◆ 110 kW solar PV system

ENERGY AND COST SAVINGS

(Confirmed efficiency savings plus projected PV savings)

- ◆ 44% reduction in actual resident energy use (combined BTU savings)
- ◆ 18% cost savings in resident utility bills from energy efficiency and electrification measures
- ◆ \$830 average bill savings per unit
- ◆ 72% total site savings on BTU basis
- ◆ 91 metric tons CO2 reduced

LINK TO COMPLETE CASE STUDY:

<https://camultifamilyenergyefficiency.org/case-studies/case-studies-almond-court/>

Figure 1. Almond Court Case Study

Table 1. Savings from Example Multifamily Electrification Projects in California

Property Name	Combined Site BTU Savings	Electricity Savings	Gas Savings	Combined \$ Savings	GHG Savings
205 Jones	40%	-82%	48%	31%	34%
Padre	37%	-6%	53%	27%	30%
Marlton Manor	27%	4%	35%	49%	23%
ArdenAire	64%	-33%	89%	36%	51%
Cascade Village	50%	-84%	66%	25%	41%
North Park	32%	18%	45%	23%	28%
Average	42%	-31%	56%	32%	35%

Step 4 – Evaluate Upgrade Cost and Consider Emerging Alternatives

- Infrastructure upgrade costs
- Emerging alternatives to upgrading electrical infrastructure, current and future use cases
 - Smart panels and splitters
 - EV dynamic load management

Table 10. Estimated Costs for Electrical Infrastructure Upgrades


Electrical Infrastructure Upgrades	Cost
Add circuits for a new electric appliance	\$500–\$2,000
Upgrade subpanels	\$1,000–\$7,000
Replace disconnects at meter bank	\$1,000–\$3,000
Upsize feeder cable	\$1,000–\$10,000
Convert from single to three phase	\$10,000–\$100,000 (depends on building size)

Table 11. Estimated Costs for Utility Service Upgrades

Utility Service Upgrades	Cost
Service line disconnect	\$500–\$5,000
Overhead service connection	\$3,000–\$10,000
Underground service connection	\$10,000–\$50,000
Pole-mount transformer	\$3,000–\$5,000
Pad-mount transformer	\$10,000–\$30,000
Subsurface transformer	\$40,000–\$80,000


Emerging Alternatives

- **Smart Panels**
 - Future use cases
 - Battery control
 - Load shifting
- **Smart Splitters**
 - Future use cases
- **EV dynamic load management**
- **Dialogue with local code enforcement**



Solar PV

- Impact of solar PV on electrification
 - Tie in with electrical infrastructure upgrades
 - Types of infrastructure connections
 - Metering types
- Resilience*
 - Load shifting
 - Power outage/shutoff
 - NZE use potential
 - Hedge against utility rate escalation



**Resilience benefits of PV and batteries are mentioned in Part 1. However, resilience strategies and benefits expand well beyond those addressed in this report.*

Appendix A – Product Guides

- Retrofit equipment product guide
 - HPWHs
 - Mini-splits
 - Packaged terminal HPs
- Emerging alternatives product guide
 - Smart panels
 - Smart splitters
 - EV load management

Table 14. Ductless Mini-Split Heat Pumps (120 V)
(Redwood Energy, 2020)













Interior Wall-Mounted Fan Coil	GE Caliber Series AS12CRA	LG ¹ Mega (115v) LS-120HXV	Mitsubishi MZ-JP12WA	Gree LIV (09,12) HP115V1B	Carrier 38MAR	Haier
						
Description	1 Indoor Fan Coil	1 Indoor Fan Coil	1 Indoor Fan Coil	1 Indoor Fan Coil	1 Indoor Fan Coil	1 Indoor Fan Coil
Dimension (in) (HxWxD)	21 x 31 x 10	19 x 28 x 10	22 x 32 x 11	33 x 21 x 13	32 x 21 x 13	28 x 35 x 14
Ref. Type	R410a	R410a	R410a	R410a	R410a	R410a
Ambient Temp. Range (H/C) (F)	-4 - 115	14 - 65 / 14 - 118	-4 - 115	0 - 115	0 - 115	0 - 115
Power (W)		1,140 - 1,090	800 - 1,300	1,955		
Max Amps (A)		10.4	11.8	17		
Heating Cap. (BTU/h)	12,000	13,000	12,200	9,600; 12,500		
Cooling Cap. (BTU/h)	12,000	12,000	12,000	9,000; 12,000		
Heating (COP)	2.92	2.6	2.9	3.3		
Cooling (COP)	2.92	3.1	2.9	4.67		

Table 12. Individual (Per Apartment) Heat Pump Water Heaters (240 V)
(Redwood Energy, 2020)

Manufacturer and Product Image	Eco2 Systems	Rheem Prestige Hybrid	AO Smith Voltex Hybrid	Bradford White AeroTherm	Stiebel Eltron Accelera
					
Description	Large Volume Cold Climate CO2 Refrigerant	Hybrid: Heat Pump and Resistance	Hybrid: Heat Pump and Resistance	Hybrid: Heat Pump and Resistance	Hybrid: Heat Pump and Resistance
Gallons	43, 83, 119	40, 50, 65, 80	50, 66, 80	50, 80	58, 80
Voltage (V)	208/230	208/240	208/240	208/240	220/240
Dimension (in)	27.5H x 35W x 11D	74H x 24Diam.	69H x 27Diam.	71H x 25Diam.	60H x 27Diam.
Ref. Type	R744 (CO2)	R134a	R134a	R134a	R134a
Ambient Temp. Range (F)	-30 - 110 (cold climate)	37 - 145	45 - 109	35 - 120	42 - 108 / 6 - 42
Power (W)			4,500	550 - 4,500	650 - 1,500
Max Amps (A)	13	15 - 30	30	30	15
Heating (BTU/h)	15,400	4,200	-	-	5,800
Heating (COP)	5.0	-	-	-	-
Energy Factor	3.09 - 3.84	3.55 - 3.70	3.06 - 3.61	2.40 - 3.39	3.05 - 3.39

Appendix B – NEC Deemed Load Calculations

- Step-by-step calculation process overview
- Load calc references
- Example dwelling unit load calc worksheet
- Example calcs: laundry room and whole building

Whole Building Residential Load Calculation - NEC Section 220				
Dwelling Unit Area	1,234 ft ²			
Number of Dwelling Units	4			
Step 1 - Lighting, Small Appliance and General Loads Per NEC 220.83B				
Deemed Lighting Load Value: 3.0 Volt Amps (VA) per square foot			=	3,703 VA
	Quantity Per Unit	NEC Deemed VA Value		
Small Appliance Circuits (2 per apartment)	2	1,500	=	3,000 VA
Laundry Circuits (1 per apartment)	1	1,500	=	1,500 VA
Garbage disposals (1 per apartment)	1	1,200	=	1,200 VA
		Appliance VA Value		
Electric Cooking Rrange and Stove Top (1 per	1	7,680	=	7,680 VA
Demand factors:				
First 8 KVA have a demand factor of 100%				8,000 VA
≥ 8 KVA have a demand factor of 40%				3,633 VA
		Total	=	11,633 VA
Step 2 - Sum up HVAC Loads Per Apartment				
	Quantity Per Unit	Appliance VA Value		
New Space Conditioning Heat Pumps (1 per apartment)	1	9,000	=	9,000 VA
Step 3 - Multiply Unit Electrical Loads by Number of Units for Each Unit Type				
	Dwelling Unit Quantity	Dwelling Unit VA	Total Unit VA	
Calculated Unit Electrical Load	4	20,633	=	82,532 VA
Step 4 - Apply Whole Building Demand Factors per NEC Table 220.84				
Demand factors:				
Total VA for Property has a demand factor of 45% because the property has 3-5 dwelling units				37,140 VA
		Total	=	37,140 VA
Total Existing Volt Amps for the Multifamily Building				33,090 VA
Total Proposed Volt Amps for the Multifamily Building with New Space Conditioning Heat Pumps				37,140 VA
		Single Phase Amp Capacity Requirements		154.75 A
		Service Line Disconnect and Feeder Wire Amp Rating		200.00 A

Load Added During Electrification

Appendix C – Flagged Electrical Infrastructure

- Existing building conditions that directly impact electrification
- Explanation of each condition and why it matters
- Actions to address

Appendix C: Flagged Electrical Infrastructure

In the Data Collection Template (Figure 7), electrical infrastructure conditions that may increase a project’s complexity are flagged with an asterisk. This table provides more information about those conditions and the relative ease or difficulty they present for electrification.

Key to electrification complexity: ○ Relatively easy ● Standard complexity ● Difficult

Flagged Electrical Infrastructure	Description	Action
APARTMENT UNITS, COMMON SPACES		
Brick or lath and plaster wall assemblies and ceiling assemblies with no cavities	Wall and ceiling assemblies that are solid or that have a cavity but are difficult to open and repair (such as lath and plaster or walls and ceilings with decorative finishes) make it difficult to conceal new circuits added during electrification.	<ul style="list-style-type: none"> ○ Wall and ceiling assemblies with inaccessible cavities require new circuits to be surface mounted or run through attics and crawlspaces. This makes adding new circuits easier but less aesthetically pleasing. ● Walls and ceilings with cavities give the option of surface mounting, attic or crawlspace runs or through wall or ceiling cavities.

Thank you!



Jack Aitchison
Manager, Engineering
jaitchison@aea.us.org
510-256-5890

Report available here:

<https://www.stopwaste.org/accelerating-electrification-of-california%E2%80%99s-multifamily-buildings>